

# DECLARATION OF PERFORMANCE

According to Regulation (EU) No 305/2011 of the European Parliament and of the Council (CPR)

<b>DECLARATION OF PERF. NO.</b>	712-1-20.02 / XXXXXX-XX
<b>PRODUCT</b>	Fire curtain <b>FIBREroll (including subtypes "S" and "S200")</b>
<b>PRODUCT IDENTIFICATION (SN)</b>	XXXXXX-XX (view label on the product)
<b>INTENDED USE</b>	Vertically rolling gate for closing structure openings between adjacent fire compartments
<b>MANUFACTURER</b>	<b>AVAPS s.r.o., U Obalovny 488, 250 67 Klecany, Czech Republic</b>
<b>SYSTEM OF ASSESSMENT</b>	System 1 + System 3
<b>NOTIFIED BODY</b>	1396 (FIRES s.r.o.)
<b>HARMONISED STANDARDS</b>	EN 16034:2014 + EN 13241+A2:2016
<b>CERTIFICATE NO.</b>	1396-CPR-0154

## DECLARED PERFORMANCE OF THE PRODUCT:

ESSENTIAL CHARACTERISTICS	PERFORMANCE	HARMONISED STANDARDS
Fire resistance	up to E120 and up to EW90 (up to EW60 for subtypes "S" a "S200")	EN 16034:2014
Smoke control	S <sub>a</sub> - subtype "S" S <sub>a</sub> , S200 - subtype "S200"	
Ability to release	Released	
Self-closing	C	
Durability of ability to release	Release maintained	
Durability of self-closing against degradation	0*	
Durability of self-closing against ageing	Achieved	
Release of dangerous substances	Pass	EN 13241+A2:2016
Safe opening	Pass	
Mechanical resistance and stability	Pass	

\* Durability of release according to EN 14637 is 10 000 cycles (report FIRES-MP-012-19-AUNE).

\*\* Fabric fire resist. roll. shutter FIBREroll, type "S" and "S200", with alumin. foil on exposed side has one side classification E 180 / EW 120.

Product characteristics are in compliance with the properties listed in the table. This declaration of performance is made under the sole responsibility of the manufacturer. Signed by and on behalf of the manufacturer:

Klecany, 01.05.2020

Ing. arch Filip Novotny, CEO